

Outdoor unit		BXA50B5V1B					
Indoor unit		FTXA50G2V1BW					
Function				Heating Season			
Cooling		Yes		Average (mandatory)		Yes	
Heating		Yes		Warmer (if designated)		Yes	
				Colder (if designated)		No	
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Design Load				Seasonal efficiency			
Cooling	P _{designc}	5.00	kW	Cooling	SEER	7.33	-
heating / Average	P _{designh}	4.00	kW	heating / Average	SCOP / A	4.60	-
heating / Warmer	P _{designh}	2.16	kW	heating / Warmer	SCOP / W	5.86	-
heating / Colder	P _{designh}		kW	heating / Colder	SCOP / C		-
Declared capacity* for cooling, at indoor temperature 27(19) °C and outdoor temperature T_J				Declared capacity* for cooling, at indoor temperature 27(19) °C and outdoor temperature T_J			
T _J = 35 °C	P _{dc}	5.00	kW	T _J = 35 °C	EER _d	3.68	-
T _J = 30 °C	P _{dc}	3.69	kW	T _J = 30 °C	EER _d	5.28	-
T _J = 25 °C	P _{dc}	2.37	kW	T _J = 25 °C	EER _d	9.24	-
T _J = 20 °C	P _{dc}	1.87	kW	T _J = 20 °C	EER _d	12.03	-
Declared capacity* for heating / Average season , at indoor temperature 20 °C and outdoor temperature T_J				Declared coefficient of performance* / Average season , at indoor temperature 20 °C and outdoor temperature T_J			
T _J = -7 °C	P _{dh}	3.54	kW	T _J = -7 °C	COP _d	3.16	-
T _J = 2 °C	P _{dh}	2.16	kW	T _J = 2 °C	COP _d	4.46	-
T _J = 7 °C	P _{dh}	1.71	kW	T _J = 7 °C	COP _d	6.32	-
T _J = 12 °C	P _{dh}	1.52	kW	T _J = 12 °C	COP _d	7.25	-
T _J = Bivalent temperature	P _{dh}	3.54	kW	T _J = Bivalent temperature	COP _d	3.16	-
T _J = operating limit	P _{dh}	3.19	kW	T _J = operating limit	COP _d	2.98	-
Declared capacity* for heating / Warmer season , at indoor temperature 20 °C and outdoor temperature T_J				Declared coefficient of performance* / Warmer season , at indoor temperature 20 °C and outdoor temperature T_J			
T _J = 2 °C	P _{dh}	2.16	kW	T _J = 2 °C	COP _d	4.46	-
T _J = 7 °C	P _{dh}	1.71	kW	T _J = 7 °C	COP _d	6.32	-
T _J = 12 °C	P _{dh}	1.52	kW	T _J = 12 °C	COP _d	7.25	-
T _J = Bivalent temperature	P _{dh}	2.16	kW	T _J = Bivalent temperature	COP _d	4.46	-
T _J = operating limit	P _{dh}	2.16	kW	T _J = operating limit	COP _d	4.46	-
Declared capacity* for heating / Colder season , at indoor temperature 20 °C and outdoor temperature T_J				Declared coefficient of performance* / Colder season , at indoor temperature 20 °C and outdoor temperature T_J			
T _J = -7 °C	P _{dh}		kW	T _J = -7 °C	COP _d		-
T _J = 2 °C	P _{dh}		kW	T _J = 2 °C	COP _d		-
T _J = 7 °C	P _{dh}		kW	T _J = 7 °C	COP _d		-
T _J = 12 °C	P _{dh}		kW	T _J = 12 °C	COP _d		-
T _J = Bivalent temperature	P _{dh}		kW	T _J = Bivalent temperature	COP _d		-
T _J = operating limit	P _{dh}		kW	T _J = operating limit	COP _d		-
T _J = -15 °C	P _{dh}		kW	T _J = -15 °C	COP _d		-
Bivalent temperature				operating limit			
heating / Average	T _{biv}	-7	°C	heating / Average	T _{ol}	-10	°C
heating / Warmer	T _{biv}	2	°C	heating / Warmer	T _{ol}	2	°C
heating / Colder	T _{biv}		°C	heating / Colder	T _{ol}		°C
Cycling interval capacity				Cycling interval efficiency			
for cooling	P _{cycc}		kW	for cooling	EER _{cycc}		-
for heating	P _{cych}		kW	for heating	COP _{cycc}		-
Degradation co-efficient cooling**	C _{dc}	0.25	-	Degradation co-efficient cooling**	C _{dh}	0.25	-
Electric power input in power models other than 'active mode'				Annual electricity consumption			
Off mode	P _{off}	0.001	kW	Cooling	Q _{CE}	239	kWh/a
Standby mode	P _{sb}	0.001	kW	heating / Average	Q _{HE}	1,218	kWh/a
Thermostat-off mode	P _{TO}	0	kW	heating / Warmer	Q _{HE}	516	kWh/a
Crankcase heater mode	P _{CK}	0	kW	heating / Colder	Q _{HE}		kWh/a
Capacity control				Other items			
Fixed	N			Sound power level (indoor/outdoor)	L _{WA}	60.0 / 62.0	db(A)
Staged	N			Global warming potential	GWP	675	kgCO ₂ eq.
Variable	N			Rated air flow (indoor/outdoor)	-	13.5 / 46.6	m ³ /min
Contact details for obtaining more information				Daikin Europe N.V. Zandvoordestraat 300, B-8400 Oostende, Belgium			

* for staged capacity units, two values divided by a slash (/) will be declared in each box in the section 'Declared capacity of the unit' and 'Declared EER/COP' of the unit.

** if default Cd = 0.25 is chosen then (results from) cycling tests are not required. Otherwise either the heating or cooling cycling test value is required.