Outdoor unit	RXA20A5V1B8						
Indoor unit	FTXA20C2V1BS						
Function				Heating Season			
Cooling	Yes			Average (mandatory) Warmer (if designated)	Yes Yes		
Heating	Yes			Colder (if designated)	No		
	b	h	h	1		h	h
ltem Design Load	Symbol	Value	Unit	Item Seasonal efficiency	Symbol	Value	Unit
Cooling	Pdesignc	2.00	kW	Cooling	SEER	8.75	
heating / Average	Pdesignh	2.40	kW	heating / Average	SCOP / A	5.15	-
heating / Warmer heating / Colder	Pdesignh Pdesignh	1.30	kW kW	heating / Warmer heating / Colder	SCOP / W SCOP / C	6.31	F .
							-
Declared capacity* for cooling, at indoor temperature 27(19) °C and outdoor temperature Tj				Declared capacity* for cooling, at indoor temperature 27(19) °C and outdoor temperature TJ			
Tj = 35°C	Pdc	2.00	kW	Tj = 35°C	EERd	4.70	-
Tj = 30 °C Tj = 25 °C	Pdc Pdc	1.48 0.95	kW kW	Tj = 30 ° C Tj = 25 ° C	EERd EERd	6.94 10.27	t
Tj = 20 °C	Pdc	0.95	kW	$T_j = 20^{\circ}C$	EERd	16.19	-
Declared capacity* for heating / Average season , at indoor temperature 20 °C and			Declared coefficient of performance* / Average season, at indoor temperature 20 °C and outdoor				
outdoor temperature Tj	D-11-	0.40	1.347	temperature Tj		0.50	
Tj = -7°C Tj = 2°C	Pdh Pdh	2.13 1.30	kW kW	Tj = -7°C Tj = 2°C	COPd COPd	3.56 5.14	Ē.
Tj = 7°C	Pdh	0.92	kW	$T_j = Z \circ C$ $T_j = 7 \circ C$	COPd	6.52	[.
Tj = 12°C	Pdh	1.08	kW	Tj = 12°C	COPd	8.24	ŀ
Tj = Bivalent temperature	Pdh	2.13	kW	Tj = Bivalent temperature	COPd	3.56	-
Tj = operating limit	Pdh	2.04	kW	Ti = operating limit	COPd	3.27	-
Declared capacity* for heating / Warmer season , at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance* / Warmer season, at indoor temperature 20 °C and outdoor temperature Ti			
Tj = 2°C	Pdh	1.30	kW	Tj = 2°C	COPd	5.14	-
Tj = 7°C	Pdh	0.92	kW	Tj = 7°C	COPd	6.52	-
Tj = 12 °C Tj = Bivalent temperature	Pdh Pdh	1.08 1.30	kW kW	Tj = 12°C Tj = Bivalent temperature	COPd COPd	8.24	F
$T_j = operating limit$	Pdh	1.30	kW	$T_j = \text{operating limit}$	COPd	5.14 5.14	
	at indeer tomporatu	- 20 *C	and		at indeer tom	noratura 20 °C ar	ad outdoor
Declared capacity* for heating / Colder season , at indoor temperature 20 °C and outdoor temperature 11 Ti = -7°C Pdh kW			Declared coefficient of performance* / Colder season, at Indoor temperature 20 °C and outdoor temperature T1 Tip = -7°C COPd				
Tj = 2°C	Pdh		kW	$T_j = 2^{\circ}C$	COPd		-
Tj = 7°C	Pdh		kW	Tj = 7°C	COPd		-
Tj = 12°C	Pdh		kW	Tj = 12°C	COPd		-
Tj = Bivalent temperature	Pdh		kW	Tj = Bivalent temperature	COPd		-
Tj = operating limit Tj = -15°C	Pdh Pdh		kW kW	$T_j = operating limit$ $T_j = -15 ^{\circ}C$	COPd COPd		-
	i di			1	0010		
Bivalent temperature	here :	-	1.0	operating limit	F 1	140	1.0
heating / Average heating / Warmer	Tbiv Tbiv	-7 2	°C °C	heating / Average heating / Warmer	Tol Tol	-10 2	°C °C
heating / Colder	Tbiv	2	• <u>c</u>	heating / Colder	Tol	٤	<u>°C</u>
Cycling interval capacity				Cycling interval efficiency			
for cooling	Pcycc		kW	for cooling	EERcyc		
for heating	Pcych		kW	for heating	COPcyc		
Degradation co-efficient cooling**	Cdc	0.25	-	Degradation co-efficient cooling**	Cdh	0.25	-
Electric power input in power models other than 'active mode'				Annual electricity consumption			
Off mode	Poff	0.001	kW	Cooling	^Q CE	80	kWh/a
Standby mode	. .	0.001	kW	heating / Average	h	652	kWh/a
	Psb				QHE		
Thermostat-off mode	РТО	0	kW	heating / Warmer	QHE	289	kWh/a
Crankcase heater mode	Devi	0	kW	heating / Colder	h		kWh/a
	PCK				QHE		
Capacity control		7		Other items			
Fixed	N			Sound power level (indoor/outdoor)	1	57.0 / 59.0	db(A)
					└WA		
Staged	Ν			Global warming potential	GWP	675.0	kgCO2eq.
Variable	N			Rated air flow (indoor/outdoor)	-	11.0 / 34.0	m ³ /min
L				L			/
Daikin Europe N.V. Zandvoordestraat 300, B-8400 Oostende, Belgium Contact details for obtaining more information							
* for stagod consoity upite, the values divide the	a alaah (/) will be the	olored 's	000h h -	v in the section (Declared specify of the unit) and (Declared		P' of the unit	
I I I SIAGED CAPACITY UNITS, TWO VAILIES DIVIDED BY	a siasii (/) Will De de	sciared in	each do	x in the section 'Declared capacity of the unit' and 'Decla	IEU EEK/GO	- oi trie dhit.	

** if default Cd = 0,25 is chosen then (results from) cycling tests are not required. Otherwise either the heating of cooling cycling test value is required.