Outdoor unit Indoor unit	RXA35A5V1B8 FTXA35C2V1BS							
Function   Unating Consess								
Function Cooling	Yes			Heating Season Average (mandatory)	Yes			
Heating	Yes			Warmer (if designated)	Yes			
				Colder (if designated)	No			
lån	Combal	Malua	l Inia	1	Combal	Malue	11-1-	
ltem Design Load	Symbol	Value	Unit	Seasonal efficiency	Symbol	Value	Unit	
Cooling	Pdesignc	3.40	kW	Cooling	SEER	8.73	Į.	
heating / Average	Pdesignh	2.50	kW	heating / Average	SCOP / A	5.15	-	
heating / Warmer	Pdesignh	1.35	kW	heating / Warmer	SCOP / W	6.29	ŀ	
heating / Colder	Pdesignh		kW	heating / Colder	SCOP / C			
Declared capacity* for cooling, at Indoor temperature 27(19) °C and outdoor temperature Ti				Declared capacity* for cooling, at indoor temperature 27(19) °C and outdoor temperature Tj				
Tj = 35°C	Pdc	3.40	kW	Tj = 35°C	EERd	4.37	-	
Tj = 30 ° C	Pdc	2.51	kW	Tj = 30°C	EERd	6.46	-	
Tj = 25 ° C	Pdc	1.62	kW	Tj = 25°C	EERd	10.11	-	
Tj = 20 ° C	Pdc	0.98	kW	Tj = 20°C	EERd	16.09	-	
Declared capacity* for heating / Average season , at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance* / Average season, at indoor temperature 20 °C and outdoor temperature Ti				
Tj = -7°C	Pdh	2.22	kW	Tj = -7°C	COPd	3.58	-	
Tj = 2°C	Pdh	1.35	kW	Tj = 2°C	COPd	5.12	ŀ	
Tj = 7°C	Pdh	0.94	kW	Tj = 7°C	COPd	6.44	ŀ	
Tj = 12°C	Pdh Pdh	1.10 2.22	kW kW	Tj = 12°C	COPd	8.08	ŀ	
Tj = Bivalent temperature Tj = operating limit	Pdh	2.22	kW	Tj = Bivalent temperature Tj = operating limit	COPd COPd	3.58 3.20	[	
Declared capacity* for heating / Warmer season , at indoor temperature 20 °C and				Declared coefficient of performance* / Warmer season, at indoor temperature 20 °C and outdoor				
outdoor temperature Tj	ln.u.	4.05	h.sar	temperature Tj	loop.i	E 40		
Tj = 2°C Tj = 7°C	Pdh Pdh	1.35 0.94	kW kW	Tj = 2°C   Tj = 7°C	COPd COPd	5.12 6.44	į.	
Tj = 12°C	Pdh	1.10	kW	Tj = 7 C   Tj = 12°C	COPd	8.08		
Tj = Bivalent temperature	Pdh	1.35	kW	Tj = Bivalent temperature	COPd	5.12	-	
Tj = operating limit	Pdh	1.35	kW	Tj = operating limit	COPd	5.12	-	
Declared capacity* for heating / Colder season , at Indoor temperature 20 °C and outdoor temperature Ti			Declared coefficient of performance* / Colder season, at Indoor temperature 20 °C and outdoor temperature TI					
Tj = -7°C	Pdh		kW	Tj = -7°C	COPd		-	
Tj = 2°C	Pdh		kW	Tj = 2°C	COPd		-	
Tj = 7°C	Pdh		kW	Tj = 7°C	COPd		-	
Tj = 12°C	Pdh		kW	Tj = 12°C	COPd		-	
Tj = Bivalent temperature Tj = operating limit	Pdh Pdh		kW kW	Tj = Bivalent temperature Tj = operating limit	COPd COPd		Ī.	
Tj = -15°C	Pdh		kW	Ti = -15°C	COPd		[	
p 900				1	, , , , ,			
Bivalent temperature				operating limit				
heating / Average	Tbiv	-7	°C	heating / Average	Tol	-10	°C	
heating / Warmer	Tbiv	2	l°C	heating / Warmer	Tol	2	l·c	
heating / Colder	Tbiv		°C	heating / Colder	Tol		°C	
Cycling interval capacity				Cycling interval efficiency				
for cooling	Pcycc		kW	for cooling	EERcyc		-	
for heating	Pcych		kW	for heating	COPcyc		-	
Degradation co-efficient cooling**	Cdc	0.25	-	Degradation co-efficient cooling**	Cdh	0.25	ŀ	
Electric power input in power models other than 's		Annual electricity consumption						
Off mode	Poff	0.001	kW	Cooling	QCE	136	kWh/a	
Standby mode		0.001	kW	heating / Average		680	kWh/a	
	Psb				OHE			
Thermostat-off mode	РТО	0	kW	heating / Warmer	ФНЕ	301	kWh/a	
Crankanan hantar mada	'	0	1.34/	hasting (Caldar			kWh/a	
Crankcase heater mode	PCK	U	kW	heating / Colder	QHE		KVVII/A	
Capacity control		1		Other Items				
Fixed	N	Ī		Sound power level (indoor/outdoor)	114/4	60.0 / 61.0	db(A)	
Staged	N			Global warming potential	LWA GWP	675.0	kgCO <b>ɔ</b> eq.	
							_	
Variable	N	]		Rated air flow (indoor/outdoor)	<u> </u>	11.9 / 36.0	<sub>m</sub> 3 <sub>/min</sub>	
Daikin Europe N.V. Zandvoordestraat 300, B-8400 Oostende, Belgium  Contact details for obtaining more information								
* for staged capacity units, two values divided by	a slash (/) will be de	clared in	each bo	x in the section 'Declared capacity of the unit' and 'Decla	red FFR/COI	of the unit		

\*\* if default Cd = 0,25 is chosen then (results from) cycling tests are not required. Otherwise either the heating of cooling cycling test value is required.