Outdoor unit Indoor unit	RXA42B5V1B9 FTXA42C2V1BB							
Function Cooling	Yes			Heating Season Average (mandatory)	Yes			
Heating	Yes			Warmer (if designated)	Yes			
				Colder (if designated)	No			
lån	Combal	Value	l Inia	1	Cumbal	Value	11-14	
ltem Design Load	Symbol	Value	Unit	Seasonal efficiency	Symbol	Value	Unit	
Cooling	Pdesignc	4.20	kW	Cooling	SEER	7.50	L.	
heating / Average	Pdesignh	3.80	kW	heating / Average	SCOP / A	4.60	-	
heating / Warmer	Pdesignh	2.05	kW	heating / Warmer	SCOP / W	5.87	ļ.	
heating / Colder	Pdesignh		kW	heating / Colder	SCOP / C			
Declared capacity* for cooling, at indoor temperature 27(19) °C and outdoor temperature Ti				Declared capacity* for cooling, at indoor temperature 27(19) °C and outdoor temperature TJ				
Tj = 35°C	Pdc	4.20	kW	Tj = 35°C	EERd	3.99	L.	
Tj = 30°C	Pdc	3.10	kW	Tj = 30°C	EERd	5.58	-	
Tj = 25 ° C	Pdc	1.99	kW	Tj = 25°C	EERd	9.35	-	
Tj = 20 ° C	Pdc	1.86	kW	Tj = 20°C	EERd	12.08	-	
Declared capacity* for heating / Average season , at indoor temperature 20 °C and outdoor temperature Ti				Declared coefficient of performance* / Average season, at indoor temperature 20 °C and outdoor temperature Tj				
Tj = -7°C	Pdh	3.37	kW	Tj = -7°C	COPd	3.16	-	
Tj = 2°C	Pdh	2.05	kW	Tj = 2°C	COPd	4.47	-	
Tj = 7°C	Pdh	1.65	kW	Tj = 7°C	COPd	6.33	-	
Tj = 12°C	Pdh Pdh	1.52	kW kW	Tj = 12°C	COPd	7.35	-	
Tj = Bivalent temperature Tj = operating limit	Pdh	3.37 3.04	kW	Tj = Bivalent temperature Tj = operating limit	COPd COPd	3.16 2.98		
Declared capacity* for heating / Warmer season , at indoor temperature 20 °C and				Declared coefficient of performance* / Warmer season, at indoor temperature 20 °C and outdoor				
outdoor temperature Tj	L		L	temperature Tj	l :	=		
Tj = 2°C	Pdh	2.05	kW	Tj = 2°C	COPd	4.47	-	
Tj = 7°C Tj = 12°C	Pdh Pdh	1.65 1.52	kW kW	Tj = 7°C Tj = 12°C	COPd COPd	6.33 7.35		
Tj = Bivalent temperature	Pdh	2.05	kW	Tj = Bivalent temperature	COPd	4.47		
Ti = operating limit	Pdh	2.05	kW	Ti = operating limit	COPd	4.47	-	
Declared capacity* for heating / Colder season , at indoor temperature 20 °C and outdoor temperature Ti				Declared coefficient of performance* / Colder season, at Indoor temperature 20 °C and outdoor temperature TI				
Tj = -7°C	Pdh		kW	Tj = -7°C	COPd		-	
Tj = 2°C	Pdh		kW	Tj = 2°C	COPd		-	
Tj = 7°C	Pdh		kW	Tj = 7°C	COPd		-	
Tj = 12°C	Pdh		kW	Tj = 12°C	COPd		-	
Tj = Bivalent temperature	Pdh		kW	Tj = Bivalent temperature	COPd		-	
Tj = operating limit Tj = -15°C	Pdh Pdh		kW kW	Tj = operating limit Tj = -15°C	COPd COPd			
11 10 0	ji dii		ice v	[1]= 13 0	JOOI U			
Bivalent temperature				operating limit				
heating / Average	Tbiv	-7	°C	heating / Average	Tol	-10	°C	
heating / Warmer	Tbiv	2	l∘c	heating / Warmer	Tol	2	l°C	
heating / Colder	Tbiv		°C	heating / Colder	Tol		<u>°C</u>	
Cycling interval capacity				Cycling interval efficiency				
for cooling	Pcycc		kW	for cooling	EERcyc		-	
for heating	Pcych		kW	for heating	COPcyc		-	
Degradation co-efficient cooling**	Cdc	0.25	-	Degradation co-efficient cooling**	Cdh	0.25	-	
Electric power input in power models other than 's	active mode'		Annual electricity consumption					
Off mode	Poff	0.001	kW	Cooling	оСЕ	196	kWh/a	
L	OII		l		OL			
Standby mode	^P sb	0.001	kW	heating / Average	QНЕ	1,156	kWh/a	
Thermostat-off mode		0	kW	heating / Warmer	L	489	kWh/a	
Thomastat on mode	PTO		I	lisating, value	QHE	100		
Crankcase heater mode	PCK	o	kW	heating / Colder	ФНЕ		kWh/a	
	Į.	! !	_		!	_		
Capacity control	L.			Other items		0001000	In as	
Fixed	N	1		Sound power level (indoor/outdoor)	ĿWA	60.0 / 62.0	db(A)	
Staged	N			Global warming potential	GWP	675	kgCO ɔ eq.	
Voriable	N			Poted air flow (indeer/outdeer)		13.1 / 45.4	_	
Variable		l		Rated air flow (indoor/outdoor)	Ι	13.1 / 43.4	_m 3 _{/min}	
Daikin Europe N.V. Zandvoordestraat 300, B-8400 Oostende, Belgium Contact details for obtaining more information								
* for staged capacity units, two values divided by	a slash (/) will he de	clared in	each ho	x in the section 'Declared capacity of the unit' and 'Decla	red FER/COF	P' of the unit		

for staged capacity units, two values divided by a slash (/) will be declared in each box in the section 'Declared capacity of the unit' and 'Declared EER/COP' of the unit.

if default Cd = 0,25 is chosen then (results from) cycling tests are not required. Otherwise either the heating of cooling cycling test value is required.