Outdoor unit Indoor unit	RXP50N5V1B FTXP50N2V1B							
unction				Heating Season				
Cooling Heating	Yes Yes			Average (mandatory) Warmer (if designated)	Yes Yes	Yes		
reduring	103			Colder (if designated)				
				To the state of th				
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit	
Design Load	I		1	Seasonal efficiency	1			
Cooling	Pdesignc	5.0	kW	Cooling	SEER	7.30	-	
heating / Average	Pdesignh	4.60	kW kW	heating / Average	SCOP / A SCOP / W	4.40 5.72	ľ	
heating / Warmer heating / Colder	Pdesignh Pdesignh	2.48	kW	heating / Warmer heating / Colder	SCOP / W	5.72		
ricating / Golder	i designin		1000	reating / Golder	10001 70		-	
Declared capacity* for cooling, at indoor temperature 27(19) °C and outdoor temperature Tj				Declared capacity* for cooling, at indoor temperature 27(19) °C and outdoor temperature Tj				
Tj = 35°C	Pdc	5.00	kW	Tj = 35°C	EERd	3.61	-	
Tj = 30 ° C	Pdc	3.68	kW	Tj = 30°C	EERd	5.08	-	
Tj = 25°C	Pdc Pdc	2.37 2.12	kW kW	Tj = 25°C	EERd	8.90 13.9	ŀ	
Tj = 20 ° C	Puc	2.12	KVV	Tj = 20°C	EERd	13.9	r	
Declared capacity* for heating / Average season , at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance* / Average season, at indoor temperature 20 °C and outdoor temperature Ti				
Tj = -7°C	Pdh	4.07	kW	Tj = -7°C	COPd	2.76	-	
Tj = 2°C	Pdh	2.48	kW	Tj = 2°C	COPd	4.46	ŀ	
Tj = 7°C	Pdh	1.59	kW	Tj = 7°C	COPd	5.69	r	
Tj = 12°C	Pdh Pdh	1.60	kW kW	Tj = 12°C	COPd	7.11	ľ	
Tj = Bivalent temperature Tj = operating limit	Pdh	4.07 3.15	kW	Tj = Bivalent temperature Tj = operating limit	COPd COPd	2.76 2.39		
	•			Declared coefficient of performance* / Warmer season,	•	•	nd outdoor	
				temperature Tj				
Tj = 2°C	Pdh	2.48	kW	Tj = 2°C	COPd	4.46	-	
Tj = 7°C	Pdh	1.59	kW	Tj = 7°C	COPd	5.69	-	
Tj = 12°C	Pdh	1.60	kW	Tj = 12°C	COPd	7.11	ŀ	
Tj = Bivalent temperature	Pdh	2.48	kW	Tj = Bivalent temperature	COPd	4.46	r	
Tj = operating limit	Pdh	3.15	kW	Tj = operating limit	COPd	2.39	-	
Declared capacity* for heating / Colder season , at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance* / Colder season, at Indoor temperature 20 °C and outdoor temperature TI				
Tj = -7°C	Pdh		kW	Tj = -7°C	COPd		-	
Tj = 2°C	Pdh		kW	Tj = 2°C	COPd		-	
Tj = 7°C	Pdh		kW	Tj = 7°C	COPd		-	
Tj = 12°C	Pdh		kW	Tj = 12°C	COPd		-	
Tj = Bivalent temperature Tj = operating limit	Pdh Pdh		kW kW	Tj = Bivalent temperature	COPd COPd		-	
Tj = -15°C	Pdh		kW	Tj = operating limit  Tj = -15°C	COPd			
10 0	j. 011			101-10-0	100. 0			
Bivalent temperature				operating limit				
heating / Average	Tbiv	-7.0	°C	heating / Average	Tol	-15	°C	
heating / Warmer	Tbiv	2	l°C	heating / Warmer	Tol	-15	l°C	
heating / Colder	Tbiv		°C	heating / Colder	Tol		<u>°C</u>	
Cycling interval capacity				Cycling interval efficiency				
for cooling	Pcycc		kW	for cooling	EERcyc		-	
for heating	Pcych		kW	for heating	COPcyc		-	
Degradation co-efficient cooling**	Cdc	0.25	-	Degradation co-efficient cooling**	Cdh	0.25	-	
Electric power input in power models other than 's	orthe mode'		Annual electricity consumption					
Off mode	_	0.001	kW	Cooling		240	kWh/a	
	Poff			g	QCE			
Standby mode	<sup>P</sup> sb	0.001	kW	heating / Average	ФНЕ	1,463	kWh/a	
Thermostat-off mode	РТО	0	kW	heating / Warmer	ФНЕ	607	kWh/a	
Crankanan hantar mada	'		1.34/	backing / Caldar			ls\A/lb/a	
Crankcase heater mode	PCK	U	kW	heating / Colder	QHE		kWh/a	
Capacity control		1		Other items				
Fixed	N	İ		Sound power level (indoor/outdoor)		59.0 / 61.0	db(A)	
	N				LWA GWP			
Staged				Global warming potential	GVVF	675	kgCO2eq.	
Variable	N			Rated air flow (indoor/outdoor)	-	16.3 / 41.0	<sub>m</sub> 3 <sub>/min</sub>	
Daikin Europe N.V. Zandvoordestraat 300, B-8400 Oostende, Belglum  Contact details for obtaining more information								
* for staged capacity units, two values divided by	a slash (/) will be de	clared in	each ho	x in the section 'Declared capacity of the unit' and 'Declar	red EEB/COE	of the unit		

for staged capacity units, two values divided by a slash (/) will be declared in each box in the section 'Declared capacity of the unit' and 'Declared EER/COP' of the unit.

'\* if default Cd = 0,25 is chosen then (results from) cycling tests are not required. Otherwise either the heating of cooling cycling test value is required.